



## **REQUEST FOR BID**

St. Croix County, Wisconsin  
RFB for Glen Hills Park Toilet Room Facility

### **Addendum with Answers to Questions:**

1. Do we have to bid to the General Contractors, or will the County accept individual bids for specific construction portions?
  - a. The County will accept specific bids for electrical, plumbing, etc., however, it will be up to the General Contractor to determine if they would like to use these individual bids.
2. The electrical plan requires additional detail for hand dryers.
  - a. Electrical contractor to provide 120V power connections to four Electric Hand Dryers (see Architectural plan for hand dryer locations).
  - b. Hand dryers to be circuited individually to 20A single pole breakers in Panel P1 (one circuit per hand dryer).
3. Specification Section 07 2100 Thermal Insulation: Under 2.02, 12, add "DiversiFoam Products, [www.diversifoam.com](http://www.diversifoam.com)"; Certifoam 15 as acceptable manufacturer.
4. Drawing 10/ A-101 Floor Plan:
  - a. Items listed as Paper Towel Dispensers are intended to be Electric Hand Dryers per specification Section 10 2800. 4 thus.
  - b. Sanitary Napkin Disposals are to be located adjacent to the Toilet Paper Dispensers at WC side wall and mounted per 20/A-401. 4 thus.
5. Section 00 4100 BSD-Bid Form does not have the bond percentage listed. Bond percentage will be 5% of the bid amount (new form attached).
6. Specification Section 07 4113 Metal Roof Panels: Under 2.01, add "Firestone Building Products, UNA-CLAD UC-4, [www.firestonebpc.com](http://www.firestonebpc.com)"; as acceptable manufacturer.